


**Copy of the certificate regarding Water, Health & Sanitation issued by  
Medical Officer, Ahmedabad**

**Annexure C**

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

No. \_\_\_\_\_ Dated: 24.03.2025  
It is certified that an inspection team headed by Dr. Gopal N. Kulumbé  
(Name of Officers with designation) from Hi-Tech Healthcare PHED  
inspected the IDP School, South bopal, Ahmedabad.  
(Name & Address of the school) on 19.03.2025 (date of inspection) and on the basis of  
Water Test Report (Attached) bearing no. HTL/W/250319019 dated 24.03.2025  
of Hi-Tech Healthcare (PHED Lab) certified that the  
IDP School, Ahmedabad (Name of school) has safe drinking water  
facilities for the students and members of staff of the institution. School is also maintains the  
hygienic sanitation condition in the school building & the campus as per norms prescribed by the  
Central/ State/ U.T. Govt.

This certificate is valid till 24.03.2026

Dr. Gopal N. Kulumbé  


Signature with Seal: Dr. Gopal N. Kulumbé  
Name: Dr. Gopal N. Kulumbé  
Designation: Tech. Director  
Name & Address of the Office / Department: \_\_\_\_\_

To IDP School, NR. Shivvi  
Nirman Estate, South bopal, A'Bad.  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

**PRINCIPAL**  
Ruloma Janahi  
**IDP SCHOOL**  
**SOUTH BOPAL**

**SANTOSH FOUNDATION**  
P. Singh  
**M. Trustee/Trustee**

# Copy of the water Examination Report



201-202, Sahaj Arcade, Opp. Lincoln Healthcare,  
B/h. Sarjan Arcade, Near Sola Gam,  
Science City Road, Ahmedabad-380 060  
Ph. : 079-40027452 M. : 9099971265



Email : hitechlabindia@gmail.com  
Web : www.hitechhealthcarelab.com

## TEST REPORT

Product Description : IS 10500: 2012, Drinking Water, Amd. 4



Report Issued To: M/s.IDP SCHOOL  
IDP SCHOOL, NR. SHANVI NIRMAL ESTELA, B/H,  
MARIGOLD CIRCLE, SOUTH BOPAL AHMEDABAD

ULR : TC761325000002632F

Issued Date: 24/03/2025

Report No. : HTL/W/250319019

### Part A: Particular of Sample Submitted

(a) Name of Sample : TAP WATER  
(c) Mode of Packing : PET BOTTLE  
(e) Sample Collection Date : 19/03/2025  
(g) Date of Receipt : 19/03/2025

(b) Quantity : 4 X 500 ML  
(d) Sample Condition : Satisfactory  
(f) Any other Information : NA

### Part B:

Date of start of Testing : 19/03/2025

Date of Completion : 24/03/2025

### Part C: Test Result

Table 1 Organoleptic and Physical Parameters (Foreword and Clause 4)

Sr.No.	Characteristic	Results	Requirement (Acceptable Limit)	Permissible Limit in absence of Alternate source	Method of Test, Ref to IS or As per SOP No.
1	Colour, Hazen Units, Max	<1	5	15	IS 3025 (Part 4)
2	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5)
3	pH value	7.97	6.5-8.5	No Relaxation	IS 3025 (Part 11)
4	Taste	Agreeable(b)	Agreeable	Agreeable	IS 3025 (Part 7 & 8)
5	Turbidity, NTU, Max.	<0.1	1	5	IS 3025 (Part 10)
6	Total Dissolved solids, mg/l, Max.	162	500	2000	IS 3025 (Part 16)

Table 2 General Parameters Concerning Substances Undesirable

Sr.No.	Characteristic	Results	Requirement (Acceptable Limit)	Permissible Limit in absence of Alternate source	Method of Test, Ref to IS or As per SOP No.
1	Calcium (as Ca), mg/l, Max.	22.89	75	200	IS 3025 (Part 40)
2	Chloride (as Cl), mg/l, Max.	12.16	250	1000	IS 3025 (Part 32)
3	Magnesium (as Mg), mg/l, Max.	13.38	30	100	IS 3025 (Part 46)
4	Nitrate (as NO <sub>3</sub> ), mg/l, Max.	5.70	45	No Relaxation	IS 3025 (Part 34)
5	Sulphate (as SO <sub>4</sub> ) mg/l, Max.	12.0	200	400	IS 3025 (Part 24)
6	Total Alkalinity (as CaCO <sub>3</sub> ), mg/l, Max.	131.34	200	600	IS 3025 (Part 23)
7	Total Hardness (as CaCO <sub>3</sub> ), mg/l, Max.	122.4	200	600	IS 3025 (Part 21)

RAJESH C PATEL  
Reviewed by



DIVYA RAVAL  
Authorized Signatory

NIKITA PATEL  
Authorized Signatory

Page No. 1/2

A BIS Recognised and ISO 9001 Certified Laboratory  
(Testing Facility Available for Drinking Water, Packaged Drinking Water, Drugs & Cosmetics and Food Items)

PRINCIPAL  
  
IDP SCHOOL  
SOUTH BOPAL

SANTOSH FOUNDATION  
  
M. Trustee/Trustee



**TEST REPORT**

Product Description : IS 10500: 2012, Drinking Water, Amd. 4



Report Issued To: M/s.IDP SCHOOL  
IDP SCHOOL, NR. SHANVI NIRMAL ESTELA, B/H,  
MARIGOLD CIRCLE, SOUTH BOPAL AHMEDABAD

ULR : TC761325000002632F

Issued Date: 24/03/2025

Report No. : HTL/W/250319019

Table 5 : Microbiological Requirements (Clause 5.1)

Sr.No.	Characteristic	Results	Requirement (Acceptable Limit)	Permissible Limit in absence of Alternate source	Method of Test, Ref to IS or As per SOP No.
1	Escherichia coli	Absent / 100ml	Absent in 100 ml	No Relaxation	IS 15185
2	Total coliform	Absent / 100ml	Absent in 100 ml	No Relaxation	IS 15185

NA= Not Applicable, NM= Not Mentioned, BLQ=Below Limit of Quantification, QL=Quantification Limit

  
RAJESH C PATEL  
Reviewed by



  
DIVYA RAVAL  
Authorized Signatory

  
NIKITA PATEL  
Authorized Signatory


**Note:**

1. This report, in full or in part, shall not be published, advertised, used for any legal action, unless prior permission has been secured from the Director of Laboratory.
2. This test report is ONLY FOR THE SAMPLE TESTED.

End of Report

Page No. 2/2

A BIS Recognised and ISO 9001 Certified Laboratory  
(Testing Facility Available for Drinking Water, Packaged Drinking Water, Drugs & Cosmetics and Food Items)

**PRINCIPAL**  
  
**IDP SCHOOL**  
**SOUTH BOPAL**

**SANTOSH FOUNDATION**  
  
**M.Trustee/Trustee**